

# Confirmation

## LEED

On May 15th, 2015, Eurofins Product Testing A/S received a sample of a Sealant with the product name:

### **Firestop Acrylic Sealant**

supplied by

### **Akkim Sealants & Adhesives**

The sample was supplied as being representative of the manufactured product, and it has been tested as Other Sealants in accordance with the relevant ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00148204).

**The test results of the tested sealant indicate that the product qualifies for LEED 2009 VOC content by complying with:**

**VOC content specifications in LEED credit EQc4.1 "Low-emitting products":**

- the requirements of SCAQMD rule 1168 (2005)

22 June 2015



---

Morten Sielemann  
Analytical Chemist